

## The Water We Drink

### JEFF DAVIS WATER AND SEWER COMMISSION NO. 1

Public Water Supply ID: LA 1053014

We are pleased to present to you the Annual Water Quality Report for the year **2024**. This report is designed to inform you about the quality of your water and the services we deliver to you every day (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien). Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the drinking quality of your water. Our water source(s) are listed below:

<u>Source Name</u>	<u>Source type</u>
Well #1 - NORTH	Ground Water
Well #2 - SOUTH	Ground Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally - occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban storm water runoff, residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants – which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We want our valued customer to be informed about their water utility. If you have any questions about this report, want to attend any scheduled meeting, or simply want to learn more about your drinking water, please contact David Trahan at 337-587-2276.

**Our water system grade is an A. Our water system report card can be found at**  
[www.jdwc1.com](http://www.jdwc1.com)

There is no safe level of lead in drinking water. Exposure to lead in drinking can cause serious health effects in all age groups, especially pregnant people, infants(both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact health care provider for more information about your risks.

The Louisiana Department of Health and Hospitals - Office of Public Health routinely monitors for contaminants in your drinking water according to Federal and State laws. The tables that follow show the results of our monitoring during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2024. Drinking water, including bottled drinking water, may be reasonably expected to contain at least some small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, the following definitions are provided:

**Parts per million (ppm) or milligrams per liter (mg/L)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or micrograms per liter (ug/L)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.

**Treatment Technique (TT)** - an enforceable procedure or level of technological performance which public water systems must follow to ensure control of a contaminant.

**Action Level (AL)** – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**Maximum Contaminant Level (MCL)** - the “Maximum Allowed” MCL is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLG’s as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG’s allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** – the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Level 1 assessment** – A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment** – A very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Our water system tested minimum of 10 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

<u>Disinfectant</u>	<u>Date</u>	<u>Highest RAA</u>	<u>Unit</u>	<u>Range</u>	<u>MRDL</u>	<u>MRDLG</u>	<u>Typical Source</u>
Chlorine	2024	1.3	ppm	0.62-2.54	4	4	Water additive used to control microbes

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

The State of Louisiana regularly monitors source water per State and Federal Regulations. Treated water samples are monitored to further evaluate compliance

<u>Source Water Regulated Contaminants</u>	<u>Collection Date</u>	<u>Highest Value</u>	<u>Range</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	<u>Typical Source</u>
BARIUM	06/02/2024	0.33	0.32-0.33	ppb	2	2	Discharged of drilling wastes; Discharge from metal refineries Erosion of natural deposits

FLUORIDE	06/02/2024	0.2	0.1-0.2	ppm	4	4	Erosion of natural Deposits; Water Additive which Promotes strong Teeth; Discharge From fertilizer and Aluminum factories
----------	------------	-----	---------	-----	---	---	---

<u>Treated Water Regulated Contaminants</u>	<u>Collection Date</u>	<u>Highest Value</u>	<u>Range</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	<u>Typical Source</u>
NITRATE-NITRITE	06/02/2024	0.2	0.2	ppm	10	10	Runoff from Fertilizer use; Leaching from Septic tanks Sewage; Erosion of Of natural deposits

<u>Source Water Radiological Contaminants</u>	<u>Collection Date</u>	<u>Highest Value</u>	<u>Range</u>	<u>Unit</u>	<u>MCL</u>	<u>MCLG</u>	<u>Typical Source</u>
GROSS BETA PARTICLE ACTIVITY	06/02/2024	3.01	2.94-3.01	pCi/l	50	0	Decay of natural and man-made deposits.

<b>Lead and Copper</b>	<b>Date</b>	<b>90<sup>th</sup> Percentile</b>	<b>Range</b>	<b>Unit</b>	<b>AL</b>	<b>Site Over AL</b>	<b>Typical Source</b>
COPPER, FREE	2020-2023	0.2	0.1- 0.4	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits: Leaching from wood preservatives
LEAD	2020-2023	3	1 -17	ppb	15	0	Corrosion of household Plumbing systems; Erosion of natural deposits

<b>Disinfection Byproducts</b>	<b>Sample Point</b>	<b>Period</b>	<b>Highest LRAA</b>	<b>Range</b>	<b>Unit</b>	<b>MCL</b>	<b>MCLG</b>	<b>Typical Source</b>
TOTAL HALOACETIC ACIDS (HAA5)	E. Racca Rd. and Hwy. 26	2023-2024	11	5.9-14.7	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	Keystone Rd. and Hwy. 382	2023-2024	8	4.1 - 9.3	ppb	60	0	By-product of drinking water disinfection
TTHM	E. Racca Rd and Hwy. 26	2023-2024	56	32.7-60.8	ppb	80	0	By-product of drinking water chlorination
TTHM	Keystone Rd. and Hwy. 382	2023-2024	40	22.9-28.2	ppb	80	0	By-product of drinking water chlorination

<b>Secondary Contaminants</b>	<b>Collection Date</b>	<b>Highest Value</b>	<b>Range</b>	<b>Unit</b>	<b>SMCL</b>
ALUMINUM	06/02/2024	0.02	0.02	MG/L	0.2
CHLORIDE	06/02/2024	153	100-153	MG/L	250
HARDNESS, TOTAL (AS CaCO3)	06/02/2024	118.5	108.1-118.5	MG/L	0
IRON	06/02/2024	0.5	0.45 - 0.5	MG/L	0.3
MANGANESE	06/02/2024	0.18	0.17 - 0.18	MG/L	0.05
PH	06/02/2024	6.57	6.51-6.57	PH	8.5
POTASSIUM	06/02/2024	1.9	1.8-1.9	MG/L	0
SODIUM	06/02/2024	112.9	82.5-112.9	MG/L	0

### +++++Environmental Protection Agency Required Health Language+++++

Some people may be more vulnerable to contaminants drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA\CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. JEFF DAVIS WATER AND SEWER COMMISSION 1 is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your and wish to have your water tested, contact JEFF DAVIS WATER AND SEWER COMMISSION NO.1 and David Trahan @ 337-587-2276. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Required Health Effects Language:

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Infants and children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of material used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking water Hotline (800-426-4761

There are no additional required health effects violation notices.

.....

Thank you for allowing us to continue providing your family with clean, quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers.

We at the Jeff Davis Water and Sewer Commission No. 1 water system work around the clock to provide top quality drinking water to every tap. We ask that all our customers help us protect and conserve our water sources, which are the heart of community, our way of life, and our children's future. Additional information on the water system can be found at [www.ldh.la.gov/watergrade](http://www.ldh.la.gov/watergrade) . We will not send each customer a copy of this report. Please call our office at 337-587-2276 if you need a hard copy or have any questions.